



# Certificate of Conformity

**Certificate:** 11457-8S\_Rev1

**Master Contract:** LC 1145831

**Project:** 11457

**Date Issued:** January 13, 2016

**Issued to:** DNH AS (Den Norske Høytalerfabrikk AS)  
Gruveveien 2-4, 3770 Kragerø  
Telemark  
Norway

**Certification System Type 3**  
(ISO / IEC Guide 67)

*The products listed below are eligible to bear the LabTest Certification Mark with adjacent indicators 'C' and 'US', and the subject area as shown below.*



**Issued by:**

Safety Testing Manager

## PRODUCTS

- **Junction Box**
  - **Model No.:** JBP-120EExeN
  - **CSA Standards Ratings:** 275V, 0.5mm<sup>2</sup>/5A, 1.5mm<sup>2</sup>/10A, 2.5mm<sup>2</sup>/16A, IP67, Ex e IIC T6 Gb LC13.11457, -50°C ≤ Ta ≤ +50°C
  - **UL Standards Ratings:** 275V, 0.5mm<sup>2</sup>/5A, 1.5mm<sup>2</sup>/10A, 2.5mm<sup>2</sup>/16A, IP67, Class 1 Zone 1 AEx e IIC T6 Gb LC13A11457 -50°C ≤ Ta ≤ +50°C

## APPLICABLE REQUIREMENTS & SUBJECT AREA

- CAN/CSA-C22.2 No. 60079-0: 2011 & UL 60079-0: 2009
- CAN/CSA-C22.2 No. 60079-7: 2012 & UL 60079-7: 2008
- CSA-C22.2 No. 60065-03:2012 & UL 60065: 2007

The 'C' and 'US' indicators adjacent to the LabTest Certification Mark shall signify that the product has been evaluated by an accredited laboratory to the applicable CSA and UL Standards respectively. The subject area shall be displayed with the LabTest Certification Mark to identify the Standard Number, and Revision Level.