

TECHNICAL DATA SHEET

This range of traditional Rotating type beacons is a cost effective solution for signalling applications where a powerful & commanding signal is required. It incorporates a parabolic reflector which, once energised, revolves around a continuously illuminated lamp. This creates a powerful beam of light that sweeps through 360°. The units are driven by a twin belt drive system that is powered by a synchronous wound motor for 'AC' units and a permanent magnet motor for 'DC' units. The RA series also incorporates an audible alarm.

Part Code:	Voltage:	Light Source:	Current:
#-13	12v Dc ---	H1 x 55 W	4.70 A
#-14	24v Dc ---	H1 x 70 W	3.00 A
#-29 •	24v Dc ---	Ba15s x 10 W	0.60 A
#-60	12v Dc ---	Ba15d x 21 W	1.85 A
#-61 •	24v Dc ---	Ba15d x 21 W	0.95 A
#-62	12v Dc ---	Ba15d x 48 W	4.00 A
#-63	24v Dc ---	Ba15d x 48 W	2.00 A
#-64	48v Dc ---	Ba15d x 35 W	0.75 A
RA201-20	12v Dc ---	H1 x 55 W	4.70 A
RA201-21	24v Dc ---	H1 x 70 W	3.00 A
RA201-64	48v Dc ---	Ba15d x 35 W	0.75 A
R400-04	115v AC ~	E14 x 60 W	0.55 A
R400-05	230v AC ~	E14 x 60W	0.29 A

code = R201/R401 units

• Diode Polarised for Fire Alarm Systems

Note: RA units have approximately a 25 mA higher current draw

Lens Colour Selection

01 = Amber, 02 = Red, 03 = Blue, 04 = Green, 05 = Clear.

Key Features

- Terminals except up to 2.5mm² cable
- Ingress Protection: Weatherproof to IP65
- Case Material: UV Stable Polycarbonate Lens, UV Stable ABS Base
- Operating Temperature: -10°C to +55°C
- Continuously Rated
- AC Supply: 50 Hz as standard
- RPM: DC operation = 160, AC operation = 120

Optional Equipment

50004 Mounting Bracket (R401/400 series only)

50010 Cage Guard (cannot be used in conjunction with wall brackets)

Magnetic mount versions available (R201 series only)

MOFLASH
SIGNALLING

INSTALLATION & TECHNICAL INFORMATION

PLEASE READ PRIOR TO INSTALLATION



ROTATING MIRROR BEACONS

R201, RA201 & R401/400>

VISUAL & AUDIBLE SIGNALLING DEVICES

APPROVALS AND
CONFORMITIES



Website: www.moflash.com

Email: technical@moflash.co.uk

Moflash part code S00429

INSTALLATION DATA SHEET

R201 and RA201 Series

Carefully twist lens firmly one turn clockwise to remove from base. Remove the inner reflector assembly from the base of the unit. Fix base to the required surface, utilising rubber gasket, with 2 x M4 screws (not supplied). Insert power cable through aperture in base & connect to terminal block on underside of reflector assembly.

For DC units connect Positive lead to the terminal block marked '+' & Negative lead to terminal block marked '-'. The termination is polarity conscious.

To Re-assemble, position the reflector assembly in the base noting the position of the three internal mounting lugs. Fix the assembly onto the lugs using the 3 x No.4 screws supplied. Replace lens onto base ensuring that the base spigot 'O' ring is in place. Twist lens one turn anti-clockwise to lock and check that the 'O' ring is positioned correctly and not caught or snagged.

R401/400 Series

Connection to this type of unit is either into the three way barrier strip situated in the base of the unit (standard connection) or via the M20 side conduit entry. If M20 is the preferred method then the two wires in the barrier strip in the base need to be unscrewed and freed from the barrier strip. Un-screw 3xNo.4 screws that retain the base plate & carefully remove, threading the wires through the aperture. Un-screw the same two wires from the internal terminal block. Carefully drill out the M20 entry & using the appropriate cable gland, insert power cable into unit connecting to the internal terminal block. Screw base plate back into position. Fix base to the required surface using the supplied gasket with 3 x M6 Hex set screws (not supplied).

Alarm Stages (Modes of Operation)

The RA series is factory wired for combined operation of the audible and visual modes.

For 3 wire control giving independent operation of either lamp or buzzer the following adjustment is required.

Ensure the supply is disconnected before attempting adjustment.

Insert a 3mm flat blade screwdriver into the inspection slot of the terminal marked '+' (see picture 1) to release the 'wire grip' and remove the Blue lead from the back of the terminal top row. Be careful not to dislodge the other Red/White/Blue leads, depending on the model. Re-insert the Blue lead into the rear of the unused middle terminal of the block (top row). Check security of all the leads. A third wire '+' can now be connected to this terminal to allow independent use of lamp and buzzer.


RA201

- '+' control of lamp
- '+' control of buzzer
- '-' common negative


General Installation Notes

- Installation must be carried out in accordance with the latest codes and regulations by a qualified electrician.
- Ensure power is disconnected prior to installation or maintenance.
- Environmental exposure conditions during installation should be dry, not moist or wet.
- The lens of the unit is Polycarbonate Plastic. Do not clean with petroleum based cleaners.
- For all installations, mount the beacon with the lens above the base. Any other mounting position will impair the IP rating (Ingress Protection) and shorten the working life of the beacon.
- Avoid mounting the beacon where it will be subject to excessive vibration.

R201 and RA201 Series



R401/400 Series



Picture 1

